



SECTION 08360

SECTIONAL OVERHEAD DOORS

Display hidden notes to specifier. (Don't know how? [Click Here](#))

PART 1 GENERAL

1.1 SECTION INCLUDES

- A. Insulated Sectional Overhead Doors.
- B. Steel Sectional Overhead Doors.
- C. Glazed Aluminum Sectional Overhead Doors
- D. Electric Operators and Controls.
- E. Operating Hardware, tracks, and support.

1.2 RELATED SECTIONS

- A. Section 03300 - Cast-In-Place Concrete: Prepared opening in concrete. Execution requirements for placement of anchors in concrete wall construction.
- B. Section 04810 - Unit Masonry Assemblies: Prepared opening in masonry. Execution requirements for placement of anchors in masonry wall construction.
- C. Section 05500 - Metal Fabrications: Steel frame and supports.
- D. Section 06114 - Wood Blocking and Curbing: Rough wood framing and blocking for door opening.
- E. Section 07900 - Joint Sealers: Perimeter sealant and backup materials.
- F. Section 08710 - Door Hardware: Cylinder locks.
- G. Section 09900 - Paints and Coatings: Field painting.
- H. Section 11150 - Parking Control Equipment: Remote door control.
- I. Section 16130 - Raceway and Boxes: Empty conduit from control station to door operator.

- J. Section 16150 - Wiring Connections: Electrical service to door operator.

1.3 REFERENCES

- A. ANSI/DASMA 102 - American National Standard Specifications for Sectional Overhead Type Doors.
- B. ASTM A 123 – Zinc hot-dipped galvanized coatings on iron and steel products.
- C. ASTM A 216 - Specifications for sectional overhead type doors.
- D. ASTM A 229 - Steel wire, oil-tempered for mechanical springs.
- E. ASTM A 653 - Steel sheet, zinc-coated galvanized by the hot-dipped process, commercial quality.
- F. ASTM D 1929 - Ignition temperature test to determine flash and ignition temperature of foamed plastics.
- G. ASTM E 84 - Tunnel test for flame spread and smoke developed index.
- H. ASTM E 330 - Structural performance of exterior windows, curtain walls, and doors by uniform static air pressure difference.
- I. ASTM E 413 - Classification for Rating Sound Insulation
- J. ASTM E 1332 - Standard Classification for Rating Outdoor-Indoor Sound Attenuation.
- K. ASTM E 283 - Standard Test Method for Determining Rate of Air Leakage Through Exterior Windows, Curtain Walls, and Doors Under Specified Pressure Differences Across the Specimen

1.4 DESIGN / PERFORMANCE REQUIREMENTS

- A. Wind Loads: Design and size components to withstand loads caused by pressure and suction of wind acting normal to plane of wall as calculated in accordance with applicable code.
 - 1. Design pressure of _____ lb/sq ft (_____ kPa).
- B. Wiring Connections: Requirements for electrical characteristics.
 - 1. 115 volts, single phase, 60 Hz.
 - 2. 230 volts, single phase, 60 Hz.
 - 3. 230 volts, three phase, 60 Hz.
 - 4. 460 volts, three phase, 60 Hz.
- C. Single-Source Responsibility: Provide doors, tracks, motors, and accessories from one manufacturer for each type of door. Provide secondary components from source acceptable to manufacturer of primary components.

1.5 SUBMITTALS

- A. Submit under provisions of Section 01300.

- B. Product Data: Manufacturer's data sheets on each product to be used, including:
 - 1. Preparation instructions and recommendations.
 - 2. Storage and handling requirements and recommendations.
 - 3. Installation methods.
- C. Shop Drawings: Indicate plans and elevations including opening dimensions and required tolerances, connection details, anchorage spacing, hardware locations, and installation details.
- D. Manufacturer's Certificates: Certify products meet or exceed specified requirements.
- E. Operation and Maintenance Data.

1.6 QUALITY ASSURANCE

- A. Manufacturer Qualifications: Company specializing in manufacturing products specified in this section with minimum five years documented experience.
- B. Installer Qualifications: Authorized representative of the manufacturer with minimum five years documented experience.
- C. Products Requiring Electrical Connection: Listed and classified by Underwriters Laboratories, Inc. acceptable to authority having jurisdiction as suitable for purpose specified.

1.7 DELIVERY, STORAGE, AND HANDLING

- A. Store products in manufacturer's unopened labeled packaging until ready for installation.
- B. Protect materials from exposure to moisture until ready for installation.
- C. Store materials in a dry, ventilated weathertight location.

1.8 PROJECT CONDITIONS

- A. Pre-Installation Conference: Convene a pre-installation conference just prior to commencement of field operations, to establish procedures to maintain optimum working conditions and to coordinate this work with related and adjacent work.

1.9 WARRANTY

- A. Warranty: Manufacturer's limited door and operators System warranty for 10 year against cracking, splitting or deterioration of steel skin due to rust-through.

PART 2 PRODUCTS

2.1 MANUFACTURERS

- A. Acceptable Manufacturer: Wayne Dalton; 2501 S. State Highway 121 Business, Suite 200, Lewisville, TX 75067. ASD. Phone: (800) 827-3667; Web Site: www.wayne-dalton.com. Email: info@wayne-dalton.com.

- B. Substitutions: Not permitted.
- C. Requests for substitutions will be considered in accordance with provisions of Section 01600.

2.2 INSULATED SECTIONAL OVERHEAD DOORS

- A. Insulated Steel Sectional Overhead Doors: Wayne Dalton Thermospan 150 insulated sectional overhead steel doors. Units shall have the following characteristics:
 - 1. Door Sections: Shall be of steel/polyurethane/steel sandwich type construction with thermal break.
 - a. Panel Thickness: 1-3/8 inches (34.92 mm).
 - b. Exterior Surface: Stucco texture and 1/4 inch wide pinstriping.
 - c. Exterior Steel: .009 inch (0.228 mm), hot-dipped galvanized.
 - d. Sections roll formed with two 1-3/4 inch integral struts sealed with polypropylene rib caps per section.
 - e. Thermal Values: R-value of 14.16; U-value of 0.071.
 - f. Air Infiltration: 0.23 cfm at 15 mph.
 - g. Sound transmission class 22 when tested in accordance with ASTM E 413.
 - h. Outdoor-indoor transmission class 19 when tested in accordance with ASTM E 1332.
 - i. Insulation: CFC-free and HCFC-free polyurethane, fully encapsulated.
 - 1) Insulated sections tested in accordance with ASTM E 84 and achieve a Flame spread Index of 10 or less, and a Smoke Developed Index of 210 or less.
 - 2) Insulation material tested in accordance with ASTM D 1929 and achieve a minimum Flash Ignition temperature of 734 degrees F, and a minimum Self Ignition temperature of 950 degrees F.
 - 3) Insulated sections shall meet all requirements of the UBC 17-5 corner burn.
 - j. Ends: Hot-dipped galvanized steel, full height with end caps.
 - 1) 18 gauge.
 - 2) 16 gauge.
 - k. Spring Counterbalance: Sized to weight of the door, with a helically wound, oil tempered torsion spring mounted on a steel shaft; cable drum of die cast aluminum with high strength galvanized aircraft cable. Sized with a minimum 5 to 1 safety factor.
 - 1) Standard cycle spring: 10,000 cycles.
 - 2) High cycle spring: 25,000 cycles.
 - 3) High cycle spring: 50,000 cycles.
 - 4) High cycle spring: 75,000 cycles.
 - 5) High cycle spring: 100,000 cycles.
 - l. Pass-Door:
 - 1) Provide with optional pass door.
 - m. Full View Alumium Glazing Sections:
 - 1) 1/8 inch (3 mm) Double Strength glass.
 - 2) 1/8 inch (3 mm) Acrylic (Plexiglass) glazing.
 - 3) 1/8 inch (3 mm) Tempered glass.
 - 4) 1/8 inch (3 mm) Polycarbonate (Lexan) glazing.
 - 5) 1/4 inch (6 mm) Tempered glass.
 - 6) 1/4 inch (6 mm) Acrylic (Plexiglass) glazing.

- 7) 1/4 inch (6 mm) Polycarbonate (Lexan) glazing.
 - 8) 1/2 inch (12.5 mm) Double Insulating glass.
 - 9) 1/2 inch (12.5 mm) Tempered Double Insulating glass.
 - 10) 1/4 inch (6 mm) Plate glass.
 - 11) 1/4 inch (6 mm) Polished wire glass.
 - 12) 1/4 inch (6 mm) Twin-Wall Polycarbonate (clear, bronze, white).
 - 13) 3/8 inch (9.5 mm) Twin-Wall Polycarbonate (clear, bronze, white).
 - 14) 5/8 inch (15.87 mm) Triple-Wall Polycarbonate (clear, bronze, white).
- n. Partial Glazing of Steel Panels set in 2-piece high-impact black polymer frame:
- 1) 1/2 inch (12.5 mm) Thermolite Insulated DSB Glass
 - 2) 1/2 inch (12.5 mm) Thermolite Insulated Tempered Glass
 - 3) 1/4 inch (6 mm) Acrylic (Plexiglass) glazing.
 - 4) 1/4 inch (6 mm) Polycarbonate (Lexan) glazing.
 - 5) 1/4 inch (6 mm) Polished wire glass.
2. Finish and Color:
- a. Two coat baked-on polyester:
 - 1) Interior color, white.
 - 2) Exterior color, white.
 - 3) Exterior color, brown.
 - 4) Exterior color, tan.
 - 5) Exterior color, gray.
 - b. Kynar:
 - 1) Interior color, white.
 - 2) Exterior color, white.
 - 3) Exterior color, brown.
 - 4) Exterior color, tan.
3. Windload Design: Provide to meet the Design/Performance requirements specified.
4. Hardware: Galvanized steel hinges and fixtures. Ball bearing rollers with hardened steel races.
5. Lock:
- a. Interior mounted slide lock.
 - b. Interior mounted slide lock with interlock switch for automatic operator.
 - c. Keyed lock.
 - d. Keyed lock with interlock switch for automatic operator.
6. Weatherstripping:
- a. Flexible bulb-type strip at bottom section.
 - b. Flexible Jamb seals.
 - c. Flexible Header seal.
7. Track: Provide track as recommended by manufacturer to suit loading required and clearances available.
- a. Size:
 - 1) 2 inch (51 mm).
 - 2) 3 inch (76 mm).
 - b. Type:
 - 1) Standard lift.
 - 2) Vertical lift.
 - 3) High lift.
 - 4) Low headroom.
 - 5) Follow roof slope.
 - c. Horizontal track shall be reinforced with continuous angle of adequate length and gauge to minimize deflection.

- d. Vertical track shall be graduated to provide wedge type weathertight closing with continuous angle mounting for steel or wood jambs, and shall be fully adjustable to seal door at jambs.
- 8. Manual Operation: Push-up.
- 9. Manual Operation: Chain hoist.
- 10. Electric Motor Operation: Provide UL listed electric operator, equal to Genie Commercial Operators, size and type as recommended by manufacturer to move door in either direction at not less than 2/3 foot nor more than 1 foot per second.
 - a. Medium Duty
 - 1) Model MH – hoist
 - 2) Model MT – trolley
 - 3) Model MJ - jackshaft
 - b. Standard Duty
 - 1) Model H – hoist
 - 2) Model T – trolley
 - 3) Model J – jackshaft
 - c. Heavy Duty
 - 1) Model GH – hoist
 - 2) Model GT - trolley
 - d. Entrapment Protection: Required for momentary contact, includes radio control operation.
 - 1) Pneumatic sensing edge up to 18 feet (5.5 m) wide. Constant contact only complying with UL 325/2010.
 - 2) Electric sensing edge monitored to meet UL 325/2010 equal to Miller Edge.
 - 3) Photoelectric sensors monitored to meet UL 325/2010.
 - e. Operator Controls:
 - 1) Push-button operated control stations with open, close, and stop buttons.
 - 2) Key operated control stations with open, close, and stop buttons.
 - 3) Push-button and key operated control stations with open, close, and stop buttons.
 - 4) Flush mounting.
 - 5) Surface mounting.
 - 6) Interior location.
 - 7) Exterior location.
 - 8) Both interior and exterior location.
 - f. Special Operation:
 - 1) Pull switch.
 - 2) Vehicle detector operation.
 - 3) Radio control operation.
 - 4) Card reader control.
 - 5) Photocell operation.
 - 6) Door timer operation.
 - 7) Commercial light package.
 - 8) Explosion and dust ignition proof control wiring.

PART 3 EXECUTION

3.1 EXAMINATION

- A. Do not begin installation until openings have been properly prepared.

- B. Verify wall openings are ready to receive work and opening dimensions and tolerances are within specified limits.
- C. Verify electric power is available and of correct characteristics.
- D. If preparation is the responsibility of another installer, notify Architect of unsatisfactory preparation before proceeding.

3.2 PREPARATION

- A. Clean surfaces thoroughly prior to installation.
- B. Prepare surfaces using the methods recommended by the manufacturer for achieving the best result for the substrate under the project conditions.

3.3 INSTALLATION

- A. Install overhead doors and track in accordance with approved shop drawings and the manufacturer's printed instructions.
- B. Coordinate installation with adjacent work to ensure proper clearances and allow for maintenance.
- C. Anchor assembly to wall construction and building framing without distortion or stress.
- D. Securely brace door tracks suspended from structure. Secure tracks to structural members only.
- E. Fit and align door assembly including hardware.
- F. Coordinate installation of electrical service. Complete power and control wiring from disconnect to unit components.
- G. Instruct Owner's personnel in proper operating procedures and maintenance schedule.

3.4 ADJUSTING

- A. Test for proper operation and adjust as necessary to provide proper operation without binding or distortion
- B. Adjust hardware and operating assemblies for smooth and noiseless operation.

3.5 CLEANING

- A. Clean doors, frames and glass using non-abrasive materials and methods recommended by manufacturer.
- B. Remove labels and visible markings.
- C. Touch-up, repair or replace damaged products before Substantial Completion.

3.6 PROTECTION

- A. Do not permit construction traffic through overhead door openings after adjustment and cleaning.
- B. Protect installed products until completion of project.

END OF SECTION